



MUNICIPAL CORPORATION, JABALPUR (M.P.)

Zone No. 02 Kachhpura, Jabalpur

No. Health Dept. / Zone / 468

Date 12/03/26


SANITARY CERTIFICATE


This is to certify that we have inspected the premises and buildings of NEW CHRIST CHURCH GIRLS' SENIOR SECONDARY SCHOOL, Scheme No. 41 Plot :- A Education Plot PanditOmkar Prasad Tiwari Nagar, Swami Vivekanand Ward, Jabalpur (M.P.) We have found the premises and surrounding areas neat and clean. The sanitary arrangements of the school such as toilets, urinals etc. are excellent and the whole atmosphere of the school is highly hygienic and commendable. There are proper arrangements for drinking water for which sufficient aqua guard machines and water coolers are available.


The above is valid for a period of 1 Year from the date of publication.

Jabalpur

Date 12/03/26


(Sanitary Inspector) (मो.)
स्वास्थ्य निरीक्षक
नगर निगम जबलपुर


(Chief Sanitary Inspector)
संभाग क्र. 02 कछपुरा
नगर निगम जबलपुर


Principal
New Christ Church Girls' Sr. Sec. School
Vijay Nagar, Jabalpur (M.P.)

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 343

Dated: 12/05/2026

It is certified that an inspection team headed by

DEEPAK KHARE (Name of Officers with designation)

from A.E. PHE. Sub. Div. Jabalpur PHED

inspected the New Christ Church Girls' Senior Secondary School, Vijay Nagar, Jabalpur (M.P.) - 482002 (Name & Address of the school) on (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. 19

dated 06.05.2026 of Dist Water Testing Lab, PHED SBT (PHED Lab)

certified that the

New Christ Church Girls' School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till Six Months only.

Khare
12/05/26

Assistant Engineer,

Signature with Seal: P.H.E. Sub-Division

Name DEEPAK KHARE, Jabalpur

Designation ASSISTANT ENGINEER

Name & Address of the Office / Department :

To New Christ Church Girls'

Sr. Sec. School (Name & Address of the Institution)

Scheme No. A1 Plot A - Padit Omkar Prasad Tiwari Nagar.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Swami Vivekanand ward, Vijay Nagar Jabalpur (M.P.)

482002

Free
Principal

New Christ Church Girls' Sr. Sec. School
Vijay Nagar, Jabalpur (M.P.)

DISTRICT WATER TESTING LABORATORY

Office of the Executive Engineer, Public Health Engg. Division Jabalpur M.P.

WATER TESTING REPORT

Report No. - 19	Date	08/05/2026	UID No. JBP/
Ref. NO. - NCCG/JBP/26	Date	05/05/2026	Village & Location
To, The Principal New Christ Church Girls Senior Secondary School, Jabalpur	1- New Christ Church Girls Senior Secondary School, Vijay Nagar Jabalpur, Campus		
Sample Collected by	School staff	2- Water Source - R.O. water	
Date of collection	05/05/2026		
Source	R.O. water		
Date of receipt	05/05/2026		
Date of Testing	06/05/2026	3-	
Test conducted by	Kavita Rajak (Chemist)		

As per BIS 10500:2012 Reaffirmed in feb 2021 For Drinking Water

Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	TEST RESULT	
					1	2

PHYSICAL-TEST

1	Turbidity	NTU	1.0	5.0	1.0	
2	Colour	Pt. Cobalt	1.0	25.0	1	
3	Taste & Odour	Agreeable	Agreeable	Agreeable	Agreeable	

CHEMICAL-TEST

4	pH	...	6.5 to 8.5	6.5 to 8.5	7.44	
5	Conductivity	M. Mohs/cm	159	
6	Alkalinity	mg/l	200	600	100	
7	Chloride (As Cl)	mg/l	250	1000	35	
8	Nitrates	mg/l	45	45	0.0	
9	Total Hardness (As CaCO ₃)	mg/l	200	600	280	
10	Calcium (As Ca)	mg/l	75	200	56.0	
11	Magnesium (As Mg)	mg/l	30	100	34.09	
12	Total dissolved solid	mg/l	500	2000	103	
13	Iron (As Fe)	mg/l	1.00	1.0	0.0	
14	Manganese (As Mn)	mg/l	0.10	0.30	0.0	
15	Fluoride (As F)	mg/l	1.00	1.50	0.36	
16	Sulphates As So ₄	mg/l	200	400	0.317	
17	Residual Chlorine	mg/l	0.20	1.0	0	

BACTERIOLOGICAL-TEST

18	Total Coliform	per 100ml	0	..	0	
19	E Coll or Thermo tolerant collforms	per 100ml	0	..	0	

Remark:-

Note:- 1. As above result compared with BIS 10500:2012

2. Samples are not collected by us.

3. Not to be produced at court of law.

4. We do not take any responsibility for deviation in test result due to wrong collection of sample

[Signature]
Principal

New Christ Church Girls' Sr. Sec. School
Vijay Nagar, Jabalpur (M.P.)

[Signature]
Chemist
In Charge District Laboratory,
P.H.E.Dn. Jabalpur