

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 209

Dated: 2/4/2025

It is certified that an inspection team headed by

(Name of Officers with designation) from A.E. P.H.E. Sub. Div. Jabalpur PHED

inspected the P.H.E. Sub. Div. Jabalpur.

(Name & Address of the school) on (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. New christ church Girls' Senior Secondary School dated

of (PHED Lab) certified that the

..... (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 01.04.2026..

Assistant Engineer

Signature with Seal: P.H.E. Sub- Division

Name: DEEPA JABALPUR

Designation: Assistant Engineer

Name & Address of the Office / Department :

To New christ church Girls' Senior Secondary School Jabalpur (M.P.)

(Name & Address of the Institution)

Scheme No. 41 Plot A Pandit Omkari Prasad Tiwari Nagar Swami Vivekanand Ward Vijay Nagar Jabalpur (M.P.)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal

New Christ Church Girls' Senior Secondary School Vijay Nagar, Jabalpur

64 | Page

MANAGER

New Christ Church Girls' Senior Secondary School
Vijay Nagar, Jabalpur (M.P.)

DISTRICT WATER TESTING LABORATORY

Office of the Executive Engineer, Public Health Engg. Division Jabalpur M.P.

WATER TESTING REPORT

Report no	176	Date	25-03-2025	Code no.	105/1
Ref. NO -	81	Date	25-03-2025	GP/Village & Location	Block
To New Christ Church Girls Sec. School, Scheme No 41 Plot A, Vijay Nagar, JABALPUR (M.P.)			New Christ Church Senior Secondary School Scheme No. 41, Plot No. A, Education Plot Pandit Omkar Prasad Tiwari Nagar, Suram Vivekanand Ward, Vijay Nagar, Jabalpur (M.P.)		
Sample Collected by	Abhishek Lwies				
Date of collection	25-03-2025				
Source	R.O. Water				
Date of receipt	25-03-2025				
Date of Testing	25-03-2025				
Test conducted by	POORNIMA SONI				

As per BIS 10500:2012 Reaffirmed in feb 2021 For Drinking Water

Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	RESULT				
					1	2	3	4	5
PHYSICAL-TEST									
1	Turbidity	NTU	1.0	5.0	0.7				
2	Colour	Pt. Cobalt			-				
3	Taste & Odour	Unobjectionable	Unobjectionable		-				
CHEMICAL-TEST									
4	pH	...	6.5 to 8.5	6.5 to 8.5	6.55				
5	Conductivity	μMohs/cm	..	..	181				
6	Alkalinity	mg/l	200	600	50				
7	Chloride (As cl)	mg/l	250	1000	45				
8	Nitrates	mg/l	45	45	0.0				
9	Total Hardness (As CaCO ₃)	mg/l	200	600	130				
10	Calcium (As Ca)	mg/l	75	200	28.0				
11	Magnesium (As Mg)	mg/l	30	100	14.61				
12	Total dissolved solid	mg/l	500	2000	117				
13	Iron (As Fe)	mg/l	1.00	1.0	0.0				
14	Manganese (As Mn)	mg/l	0.10	0.30	0.0				
15	Fluoride (As F)	mg/l	1.00	1.50	0.22				
16	Sulphates As SO ₄	mg/l	200	400	0.22				
17	Residual Chlorine	mg/l	0.20	1.0	-				
BACTERIOLOGICAL-TEST									
18	Total Coliform	per 100ml	0	..	0				
19	E Coli or Thermo tolerant coliforms or Faecal coliform	per 100ml	0	..	0				

Note:- 1. As above result compared with BIS 10500:2012

2. Samples are not collected by us.

3. Not to be produced at court of law.

4. We do not take any responsibility for deviation in test results due to wrong collection of sample

Principal

School Vijay Nagar, Jabalpur

Asstt. Chemist
Public Health Engg. Division
Jabalpur (M.P.)

MANAGER

C:\Users\ACER\Desktop\PATAN HOSPITAL 2024
New Christ Church Girls Senior Secondary School
Vijay Nagar, Jabalpur (M.P.)

testing formate 29.08.20



MUNICIPAL CORPORATION, JABALPUR (M.P.)

Zone No. 02 Kachhpura, Jabalpur

No. Health Dept./Zone 02/2024/345

Date 24/09/24

SANITARY CERTIFICATE

This is to certify that we have inspected the premises and buildings of NEW CHRIST CHURCH GIRLS' SENIOR SECONDARY SCHOOL, Scheme No. 41 Plot :- A Education Plot PanditOmkar Prasad Tiwari Nagar, Swami Vivekanand Ward, Jabalpur (M.P.). We have found the premises and surrounding areas neat and clean. The sanitary arrangements of the school such as toilets, urinals etc. are excellent and the whole atmosphere of the school is highly hygienic and commendable. There are proper arrangements for drinking water for which sufficient aqua guard machines and water coolers are available.

The above is valid for a period of 1 Year from the date of publication.

Jabalpur

Date 24/09/24

(Sanitary Inspector)
संभाग क्र. 02 कछपुरा (जी.जी.)
स्वास्थ्य निरीक्षक
नगर निगम जबलपुर

New Christ Church Girls' Senior Secondary
School Vijay Nagar, Jabalpur

(Chief Sanitary Inspector)
मुख्य स्वास्थ्य निरीक्षक
संभाग क्र. 02 कछपुरा
नगर निगम जबलपुर

Blue
MANAGER

New Christ Church Girl's Senior Secondary School
Vijay Nagar, Jabalpur (M.P.)